

Faculty of Power and Aeronautical Engineering  
Institute of Heat Engineering  
Warsaw University of Technology



# Analysis of the DVI-LOCA in the AP1000-like reactor with MELCOR2.1 code

Mateusz Włostowski<sup>1,2</sup>, Piotr Darnowski<sup>1,2</sup>

<sup>1</sup>Institute of Heat Engineering, Warsaw University of Technology, Poland

<sup>2</sup>National Atomic Energy Agency, Poland

EMUG 2024-04

# Agenda

---

- Introduction
- MELCOR Model
- Scenarios and assumptions
- Results and Discussion
- Conclusions



# Introduction

- Deterministic safety study of the AP1000 based/like plant
- Develop MELCOR code model
  - Based on public data
- Study normal operation
  - Verify steady-state with public data
- Study Design Basis Accident (DBA)
  - Verify accident response with public data
  - Preliminary step for the future severe accident research
- Modelling approach/ nodalization study
  - Study various modelling approaches
  - Plant characteristic phenomena
- Presentation based on publication:
  - *Włostowski, M., Darnowski, P. Study of the DVI-LOCA in the AP1000-like reactor with MELCOR code, Annals of Nuclear Energy 200 (2024) 110397, doi.org/10.1016/j.anucene.2024.110397*




# AP1000-like model

- AP1000 like plant MELCOR model
  - Based on public data US DCD/UK PCSR/Generic Westinghouse data
- Main relevant systems and components
  - Core & RPV
  - Reactor Coolant System – Pipework, Pumps, Pressurizer
  - All relevant safety systems
    - ❑ IRWST (In-Containment Reactors Water Storage Tank)
    - ❑ ADSs (Automatic Depressurization System)
    - ❑ ACC (Accumulators)
    - ❑ CMT (Core Make-up Tanks)
    - ❑ PRHRS (Passive Residual Heat Removal System)
  - Containment (no focus here)
  - Related control systems, setpoints, I&C






# Reactor Coolant System model

- Reactor Pressure Vessel
- Two main cooling circuits
  - Hot Legs x2
  - Cold Legs x4
  - Reactor Coolant Pump x4
- Steam Generators primary and secondary side
- Pressurizer with valves
- Main safety systems
- Valves, pumps etc.





# Core model

- Typical “detailed” MELCOR core model
- Core model for degradation
  - COR package
  - 5 radial rings, 16 axial levels
- Thermal-hydraulics model
  - CVH/FL Package
  - Superimposed on the COR package model
  - 30 CVs for core
  - 1 lower plenum
  - 1 downcomer







# Steam Generator models

- Two nodalization variants
- Simple model not allowing two-way circulation of steam/liquid in tubes
- Complex model allowing two-way circulation



# Hot Leg models



- HL nodalization study
- Three models  
Complex/Medium/Simple
- Complex with separate CVs connected to the ADS-4 and Pressurizer and RPV outlet
- Medium/Complex allowing counter-current flow
- Simple model – old style with 1 CV






# ADS-4 valves model

- Automatic Depressurization Valves Stage 4
  - Opens path to containment to assure low pressure in the RCS and operation of safety injection
- Two models
  - With separate liquid/steam flow paths
  - Without separate paths
  - Based on (Wang, 2020)



# Studied Scenario

- Direct Vessel Injection (DVI) line break
- Loss of Coolant Accident (LOCA)
  - Medium/Small break
- Design Basis Accident
- US DCD based conservative assumptions
  - DCD/PCSR NOTRUMP Westinghouse code for Small/Medium-LOCA
- Should end with safe controlled state
- Preceded with normal (steady-state) full-power operation
- It is not a severe accident. For severe accident we need additional failure.



# Results – normal state

- Reference data from US DCD
- 1000 seconds steady-state
- Very good agreement
- Allowed error (Petruzzi, 2008)

Parameter	Unit	Design value	Source of information	MELCOR	Obtained error	Allowed error
Reactor core power	MW	3400.0	DCD Table 4.4-1 (1/2)	3400	0.00%	2%
Power of primary circuit	MW	3415.0	DCD Table 5.1-3	3415	0.00%	2%
Vessel flow rate	kg/s	15 170.1	DCD Table 5.1-3	15157.9	-0.08%	2%
Core flow rate	kg/s	14 275.6	DCD Table 5.1-3	14265.7	-0.07%	2%
Inlet RPV temperature	K	553.82	DCD Table 5.1-3	554.76	0.17%	0.50%
Outlet RPV temperature	K	594.26	DCD Table 5.1-3	595.1	0.14%	0.50%
Pressurizer steam pressure	MPa	15.41	DCD Table 5.1-1	15.41	0.00%	0.10%
Developed pump head	m	111.25	DCD Table 5.4-1	111.47	0.20%	1%
Pressure drop across the core	MPa	0.275	DCD Table 4.4-1 (1/2)	0.254	-7.64%	10%
Pressure drop across the vessel, including the nozzle	MPa	0.43	DCD Table 4.4-1 (1/2)	0.471	9.53%	10%
Water volume, including pressurizer	m <sup>3</sup>	271.8	DCD Table 5.1-2	271.543	-0.09%	1%
Pressurizer water volume	m <sup>3</sup>	28.3	DCD Table 5.1-2	28.25	-0.18%	1%
Exit steam pressure	MPa	5.76	DCD Table 5.1-2	5.764	0.00%	0.10%
Steam flow	kg/s	943.7	DCD Table 5.1-2	943.96	0.03%	2%
Feedwater temperature	K	499.82	DCD Table 5.1-2	499.82	0.00%	0.50%
Steam generator secondary side water volume	m	147.9	DCD Table 5.4-5	147.00	-0.61%	2%
Steam generator secondary side vapor volume	m <sup>3</sup>	103.2	DCD Table 5.4-5	104.05	0.82%	2%

# Sequence of events for base case model

- Example DVI-LOCA sequence
- Base case model with simple SG, no complex ADS, medium HL model
- Reference results with NOTRUMP code (US DCD / UK PCSR)
- Relatively good agreement

Event [s]	US AP1000 DCD – 20 psi containment pressure	UK AP1000 PCSR – 20 psia containment pressure	MELCOR base case model
Break opens	0.0	0.0	0.0
Reactor trip signal	13.1	13.4	14.0
Steam turbine stop valves close	19.1	13.4	20.0
“S” signal	18.6	19.8	17.8
Main feed isolation valves begin to close	20.6	26.8	19.8
Reactor coolant pumps start to coast down	24.6	26.8	23.8
ADS Stage 1	182.5	181.7	192.4
ADS Stage 2	252.5	229.7	262.4
Intact accumulator injection starts	254	244.2	219.4
ADS Stage 3	372.5	349.7	382.4
ADS Stage 4	492.5	477.7	502.4
Intact accumulator empties	600.0	573.6	557.7
Intact loop IRWST injection starts (continuous injection)	1470	1778.6	~1450
Intact loop core makeup tank empties	2123	1866.0	1794.2




# Results – list of studied cases

- In this work 12 sensitivity runs simulated
- Modified SG, HL and ADS models
- Only results for complex SG presented later

Case	SG modeling	ADS-4 modeling	HL modeling	Comment
1	simple	model	fine	sensitivity
2	simple	model	medium	sensitivity
3	simple	model	coarse	sensitivity
4	simple	no model	fine	sensitivity
5	<u>simple</u>	<u>no model</u>	<u>medium</u>	<u>base model</u>
6	simple	no model	coarse	sensitivity
7	<b>complex</b>	<b>model</b>	<b>fine</b>	<b>sensitivity</b>
8	<b>complex</b>	<b>model</b>	<b>medium</b>	<b>sensitivity</b>
9	<b>complex</b>	<b>model</b>	<b>coarse</b>	<b>sensitivity</b>
10	<b>complex</b>	<b>no model</b>	<b>fine</b>	<b>sensitivity</b>
11	<b>complex</b>	<b>no model</b>	<b>medium</b>	<b>sensitivity</b>
12	<b>complex</b>	<b>no model</b>	<b>coarse</b>	<b>sensitivity</b>





# Blowdown phase

- Depressurization in 500s
- Pressure during two-phase choked flow lower – due to different choked flow models and containment pressure modelling
- Break flows in agreement
- Black lines – US DCD
- Grey lines – UK PCSR







# CMTs and ACCs

- CMT starts immediately – works as high-pressure injection
- Accumulators start at medium pressure
- Relatively good predictions



# ADS #1-3 operation





- ADS works in series with delays
- Less violent reduction in pressure and activation of subsequent injections – CMT, ACCU and IRWST
- Vapor flow predicted accurately / liquid less
- Integrated flow reasonable









# ADS #4 operation

- Final depressurization
- Vapor flow reasonable
- Liquid flow less accurate
- Integral flow relatively well predicted



# Safety injection

- IRWST low-pressure safety injection – acceptable
- Water level in downcomer reasonable
- Water inventory predicted by more complex models
- No temperature escalation – agreement with DCD/PCSR
- Core is properly covered with water



# Conclusions and summary

---

- AP1000-like MELCOR model developed
- Model verified with normal operation state
- Model verified with design basis accident
- Various modelling options explored
  - HL, SG – significant effects
  - ADS-4 – small or no effect
  - The most detailed model provides the best results
  - Using simpler models also provide relatively good results
- Model can be used in further severe accident simulations
  - MELCOR is not typical system thermal-hydraulic code.
  - MELCOR can be used to alternative DB related research.
  - MELCOR predicts quite well but not perfectly (at least for our model).
  - Code (NOTRUMP) used in DCD/PCSR is dedicated for small/medium LOCAs – MELCOR is more general.

# Acknowledgments

---

- This work was prepared as a part of the 3rd edition of the Implementation Doctorates Programme, the party of which is the **National Atomic Energy Agency** (Państwowa Agencja Atomistyki) as the employer of the first author and the **Warsaw University of Technology** as the academic institution. The **Polish Ministry of Education and Science** provided the funding for the program.
- The work reflects only the authors' view, and the National Atomic Energy Agency (PAA) and Warsaw University of Technology (WUT) are not responsible for any use that may be made of the information it contains. The authors declare that they have no known competing financial interests or personal relationships that could have appeared to influence the work reported in this paper.
- This presentation was submitted to EMUG meeting as Warsaw University of Technology controbution.

# References

- *Włostowski, M., Darnowski, P. Study of the DVI-LOCA in the AP1000-like reactor with MELCOR code, Annals of Nuclear Energy 200 (2024) 110397, doi.org/10.1016/j.anucene.2024.110397*
- *Wang, L., et al., 2020. Development and applicability analyses of ADS-4 entrainment model in large advanced PWR. Nuclear Engineering and Design 356, 110379. <https://doi.org/10.1016/j.nucengdes.2019.110379>.*
- *Petruzzi, A., D'Auria, F., 2008. Thermal-Hydraulic System Codes in Nuclear Reactor Safety and Qualification Procedures. Science and Technology of Nuclear Installations 2008, 1–16. <https://doi.org/10.1155/2008/460795>.*

# Possible bug – during UQ study for FPT-1

- COR\_LP – debris fall velocity
- When given by number
  - COR\_LP 1 1320.0 2.0E7 1.0 1 ! WORKS
  - works for M2.2.18, M2.2.21, M2.2r2023
- When given as parameter in DefineVariablesFile Variables.dat
  - COR\_LP 1 1320.0 2.0E7 {{{VFALL=1.0}}} 1 ! DOES NOT WORK !!!
  - works for M2.2.18, M2.2.21 but DOES NOT WORK for M2.2r2023

```
733: Input Pass1 : Block comments read ((( AGON )))
733: Input Pass1 : Block comments skipped ((( AGOFF )))
733: forrtl: severe (157): Program Exception - access violation
734:
734: Image                PC                Routine              Line        Source
734: melgen2_2_r2023.e    00007FF604E2221B  COR_GENERATEDB      2117       cor_generatedb.f90
734: melgen2_2_r2023.e    00007FF60446FA12  GENERATEDB          78         generatedb.f90
734: melgen2_2_r2023.e    00007FF6041ECB1F  EXEC_MEGGDB          84         meggdb_nsi.f90
734: melgen2_2_r2023.e    00007FF60414E874  M_MELGENPROG_mp_M    169        m_melgenprog.f90
734: melgen2_2_r2023.e    00007FF60414DB59  MELGEN                58         melgen.f90
734: melgen2_2_r2023.e    00007FF6061FAD6E  Unknown               Unknown     Unknown
734: melgen2_2_r2023.e    00007FF6040D104D  MAIN__                5          melgen_nsi.f90
734: melgen2_2_r2023.e    00007FF605F6280E  Unknown               Unknown     Unknown
734: melgen2_2_r2023.e    00007FF6061FCA0C  Unknown               Unknown     Unknown
734: KERNEL32.DLL         00007FFE7B414DE0  Unknown               Unknown     Unknown
735: ntdll.dll            00007FFE7D33EC4B  Unknown               Unknown     Unknown
735: PS G:\ROOT_MELCOR\FPT1\test_czemu_M22r2023_nie_dziala\MW2_2>
```



# Thank you!

Contact:

[piotr.darnowski@pw.edu.pl](mailto:piotr.darnowski@pw.edu.pl)

[mateusz.wlostowski.dokt@pw.edu.pl](mailto:mateusz.wlostowski.dokt@pw.edu.pl)



Additional slides