



**SSTC  
NRS**

STATE ENTERPRISE  
STATE SCIENTIFIC AND TECHNICAL  
CENTER FOR NUCLEAR AND  
RADIATION SAFETY

# MELCOR code use for uncertainty and sensitivity analysis of severe accident with operator actions

EMUG meeting

Vorobyov Y. (yy\_vorobyov@sstc.ua)

EMUG Meeting

Italy, Rome, April 15 - 18, 2024

# Contents

1. MELCOR model
2. Uncertainty Analysis Set-up
3. Uncertainty Analysis FOMs
4. MELCOR Runs
5. Uncertainty Analysis Results Example
6. Sensitivity Analysis Results Example
7. Code-model numerical noise/scatter
8. Code-model failure rate
9. MELCOR Uncertainty/Sensitivity Analysis Applications
10. Conclusions

# VVER-1000 Uncertainty Analysis Overview

## Overview

- Part of the work is performed in the frames of MUSA project

## MUSA

- This project has received funding from the Euratom research and training programme 2014-2018 under grant agreement No 847441



## Results

- This presentation reflects only the author's view, and the European Commission is not responsible for any use that may be made of the information it contains

# MELCOR model

## Approach

- Simple fast running model

## RCS

- Single + triple loop

## Reactor


- Simple + 6 CV core

## Secondary


- Simple SGs

## Containment


- All compartments + cavity




Reactor + HAs



Loop1 + SG1 primary



PRZR + bubbler



Secondary

# MELCOR model

## Cavities


- CAV1 under reactor
- CAV2 on containment floor

## Containment venting

- FL with filter

## Model preliminary testing


- LOOP
- LB LOCA
- SB LOCA




# MELCOR model

## Core model

- 3 rings
- 6 CV COR
- 10 axial for fuel part



Core TH nodalization



Core COR rings

Bottom elevation, m	Top elevation, m	Section height, m	HS10201	HS10203	HS10205	HS10205	
22.301	23.018	0.717	125	225	325	425	HS10224 Upper unheated part of the reactor core
21.946	22.301	0.355	124	224	324	424	HS10222 Fuel part of the reactor core
21.591	21.946	0.355	123	223	323	423	HS10220
21.236	21.591	0.355	122	222	322	422	HS10218
20.881	21.236	0.355	121	221	321	421	HS10216
20.526	20.881	0.355	120	220	320	420	HS10214
20.171	20.526	0.355	119	219	319	419	HS10212
19.816	20.171	0.355	118	218	318	418	HS10210
19.461	19.816	0.355	117	217	317	417	HS10208
19.106	19.461	0.355	116	216	316	416	HS10206
18.751	19.106	0.355	115	215	315	415	HS10204
18.525	18.751	0.226	114	214	314	414	HS10202 Bottom unheated part of the reactor core above support structures
18.348	18.525	0.177	113	213	313	413	HS10108
18.219	18.348	0.129	112	212	312	412	-
18.099	18.219	0.120	111	211	311	411	-
17.979	18.099	0.120	110	210	310	410	-
17.878	17.979	0.101000	109	209	309	409	-
17.787053	17.878	0.090947	108	208	308	408	-
17.691573	17.78705	0.095480	107	207	307	407	-
17.595671	17.69157	0.095902	106	206	306	406	-
17.509051	17.59567	0.086620	105	205	305	405	-
17.417259	17.50905	0.091792	104	204	304	404	-
17.226125	17.41726	0.191134	103	203	303	403	-
17.061902	17.22612	0.164222	102	202	302	402	-
16.899	17.0619	0.162902	101	201	301	401	-
			1	2	3	4	Reactor bottom

COR axial elevations

# Uncertainty Analysis Set-up

## Unit

- VVER-1000

## Initial Event

- Station Blackout

## Operator actions

- Open 3, 2 or 1 PORVs after enter SAMG (450C CET + delay)

## Features/Failures

- CNT venting operable (setpoints 5-3kgf/cm<sup>2</sup>, Decontamination Factor 1000)
- No ECCS
- No CNT sprays
- 1 day sequence time

## Code

- MELCOR 2.2.21402

## Uncertainty tool

- SUSA 4.0

## Number of runs

- 100 for mixed PORVs number (additional 100 for 3 PORVs open, 100 for 2 PORVs open, 100 for 1 PORV open)

## Method

- Uncertainty propagation approach
- Wilks 2<sup>nd</sup> order (93 runs min)
- Latin Hypercube sampling
- Failed cases are restarted with Dtmax change or small other params change


# Uncertainty Analysis Set-up

## Uncertainty parameters categories analyzed

- Source term phenomena
- Core heat-up
- Core degradation
- In-core thermal-hydraulics
- Corium downward motion / Corium slumping
- Corium/debris transfer to cavity
- MCCI
- Containment thermal-hydraulics
- Containment leak
- Hydrogen combustion
- Containment venting
- Equipment setpoints
- SAM (PORV opening)
- Numerics

## Methods and references

- State-of-art NUREGs
- Experiment reports
- MUSA project experience
- MELCOR code manuals
- Engineering judgment (EJ)



## Uncertainty parameters

- 43 total
- All independent



# Uncertainty Analysis Set-up

## Uncertainty parameters

- 43 total

Note* Par. #	Name	Short description	Reference value	Range of Variation	PDF Type
1	RN1_GAP00_CLFAIL	Gap Release Temperature	1173	CLFAIL = 1173 +/-100 K	Uniform
2	RN_CHI	Dynamic shape factor	1.5	CHI = 1.0 - 2.0	Uniform
3	RN_RHONOM	Aerosol density	2560	RHONOM = 1000-4120 kg/m <sup>3</sup>	Uniform
4	RN_FSLIP	Slip factor	1.257	FSLIP = 1.257 +/- 20%	Uniform
5	RN_STICK	Sticking coefficient	0.75	STICK = 0.5-1.0	Uniform
6	RN_FTHERM	Thermal accommodation coefficient	2.25	FTHERM = 2.25 +/-20%	Uniform
7	RN2_FLT_DFG	Global decontamination factor	1000	DFG= default +/- 20%	Uniform
8	COR_FCELR	Radial radiation exchange factor	0.1	FCELR = 0.1 +/- 0.05	Uniform
9	COR_FCELA	Axial radiation exchange factor	0.1	FCELA = 0.1 +/- 0.05	Uniform
10	COR_SC1104_3	Cladding emissivity	0.81	SC1104(3) = 0.81 +/-20%	Uniform
11	COR_SC1104_5	Cladding emissivity	0.76	SC1104(5) = 0.76 +/-20%	Uniform
12	COR_SC1104_1	Cladding emissivity	0.325	SC1104(1) = 0.325 +/-20%	Uniform
13	<b>DCH_TFSCAL</b>	<b>Thermal decay heat multiplier</b>	<b>1</b>	<b>TFSCAL = 1.0 +/- 0.1</b>	Uniform
14	COR_OX_SC1001(1,2)	Metallic Cladding Oxidation Rate Constant Coefficient, steam	26.7	SC1001(1,2) = 26.7 +/- 20%	Uniform
15	COR_OX_SC1001(3,2)	Metallic Cladding Oxidation Rate Constant Coefficient, oxygen	26.7	SC1001(3,2) = 26.7 +/- 20%	Uniform
16	COR_OX_SC1001(3,1)	Metallic Cladding Oxidation Rate Constant Coefficient, oxygen	87.9	SC1001(3,1) = 87.9 +/- 20%	Uniform
17	COR_OX_SC1001(1,1)	Metallic Cladding Oxidation Rate Constant Coefficient, steam	29.6	SC1001(1,1) = 29.6 +/- 20%	Uniform
18	<b>COR_EUT_TM</b>	<b>UO2-ZrO2 eutectics</b>	<b>2500</b>	<b>COR_EUT, TM = 2500 K +/- 100 K</b>	Uniform

# Uncertainty Analysis Set-up

## Uncertainty parameters

- 43 total

Note* Par. #	Name	Short description	Reference value	Range of Variation	PDF Type
19	COR_SC1131(2)	Maximum ZrO <sub>2</sub> temperature permitted to hold up molten Zr in CL	2400	SC1131(2) = 2400 K +/- 100 K	Uniform
20	COR_SC1132(1)	Temperature to which oxidized fuel rods can stand in the absence of unoxidized Zr in the cladding	2600	SC1132(1) = 2600 K +/- 100 K (UNIFORM)	Uniform
21	COR_TSSFAI	Supporting structure failure temperature	1273	TSSFAI = 1273 K +/- 100 K	Uniform
22	COR_CMT_FUOZR	Transport parameter for UO <sub>2</sub> in molten Zircaloy	0.2	FUOZR = 0.2 +/- 0.1	Uniform
23	COR_CHT_HFRZZR	Refreezing heat transfer coefficient for Zircaloy	7500	HFRZZR = 7500 +/- 5000 W/m <sup>2</sup> /K	Uniform
24	COR_CHT_HFRZZX	Refreezing heat transfer coefficient for ZrO <sub>2</sub>	7500	HFRZZX = 7500 +/- 5000 W/m <sup>2</sup> /K	Uniform
25	COR_CHT_HFRZUO	Refreezing heat transfer coefficient for UO <sub>2</sub>	7500	HFRZUO = 7500 +/- 5000 W/m <sup>2</sup> /K	Uniform
26	COR_EDR_DHYPD_CORE	Particulate Debris Equivalent Diameter (Core Region)	0.01	For core region DHYPD = 0.01m +/- 0.005m	Uniform
27	COR_EDR_DHYPD_LP	Particulate Debris Equivalent Diameter	0.002	DHYPD = 0.002m +/- 0.001m	Uniform
28	COR_ZP_PORDP	Porosity of particulate debris	0.4	PORDP = 0.4 +/- 0.1	Uniform
29	COR_LP_HDBH2O	HTC from in-vessel falling debris to pool	2000	HDBH2O = 2000 +/- 1000 W/m <sup>2</sup> /K	Uniform
30	COR_LP_VFALL	Velocity of falling debris	0.01	VFALL = 0.01 +/- 0.005	Uniform
31	CVH_SC4407(1)	Pool bubble rise velocity	0.3	SC4407(1) = 0.3 m/s +/- 0.1 m/s	Uniform
32	CVH_SC4407(11)	Pool maximum void fraction	0.4	CVH, SC4407(11) = 0.4 +/- 0.1	Uniform
33	<b>CAV_RT_NCFREL</b>	<b>Overflow height from CAV1 to CAV2</b>	<b>0.325</b>	<b>NCFREL = 0.15-0.5 m</b>	Uniform
34	CONT_LEAK_AREA_MUL	Containment leak area multiplier	1	Area VALUE +/- 50%	Uniform
35	PAR_EFF_FACTOR	PARs model efficiency multiplier	1	PAR, VALUE +/- 20%	Uniform

# Uncertainty Analysis Set-up

## Uncertainty parameters

- 43 total

Note* Par. #	Name	Short description	Reference value	Range of Variation	PDF Type
36	CFVS_Open_P	CFVS opening pressure setpoint	5	nominal setpoint of 5 bar +/-10%	Uniform
37	<b>DTMAX</b>	<b>Maximum timestep</b>	<b>0.105</b>	<b>DTMAX = 0.01 ... 0.2 s</b>	Uniform
38	<b>PORV1_AVAIL</b>	<b>PRZ PORV availability</b>	<b>3</b>	<b>PORV amount operable</b>	Discrete
39	<b>PORV_OP_DELAY</b>	<b>Time delay for manual RCS depressurization via PRZ PORV after CET increase above 450 C</b>	<b>1350</b>	<b>delay 0-2700s</b>	Uniform
40	COR_SC1020(1)	Radial debris relocation time constant (solid debris)	360	TSPRS = 180-540	Uniform
41	COR_SC1020(2)	Radial debris relocation time constant (molten debris)	60	TSPRM = 30-90	Uniform
42	CDISPN	Discharge coefficient for ejection of debris	1	CDISPN = 0.5-1.5	Uniform
43	<b>GAMMA</b>	<b>Agglomeration shape factor</b>	<b>2</b>	<b>RN, GAMMA = 1.0 3.0</b>	Uniform

**Maximum calculation  
Timestep**

**Number of PRZ SVs open with  
probability:**

**PRZ SVs open delay  
(operator action)**

**3 PORVs open 0.729**  
**2 PORVs open 0.243**  
**1 PORV open 0.027**  
**0 PORVs open 0.001**

# Uncertainty Analysis FOMs

## Variables of interest (Figures of Merits, FOMs)

- Xe release to environment (MUSA)
- Cs release to environment (MUSA)
- Cs airborne in containment
- Gap release time
- H<sub>2</sub> generation in core
- H<sub>2</sub> generation in cavities
- CFVS open time
- LH failure time
- Cavity ablation depth
- CFVS filter thermal load (aerosols)

# MELCOR Runs

## Sampled number PORVs open

### “Mixed” PORVs set

- 3, 2 or 1 PORV open (sampled)
- Other UPs sampled
- Total 100 runs

### “Mixed” PORVs set

- 3 PORVs – 72 sequences
- 2 PORVs – 25 sequences
- 1 PORV – 3 sequences

## Fixed number PORVs open

### 3 PORVs set

- Fixed 3 PORVs open
- Other UPs sampled
- Total 100 runs

### 2 PORVs set

- Fixed 2 PORVs open
- Other UPs sampled
- Total 100 runs

### 1 PORV set

- Fixed 3 PORVs open
- Other UPs sampled
- Total 100 runs



# MELCOR Runs

## MELCOR 100 runs statistics (“mixed” PORVs)

without restarts (easy cases) 9

with restarts (DT change) (medium cases) 83

with restarts (DT + param. change) (hard cases) 8



## MELCOR runs performance



# MELCOR Runs

## TH typical behavior

- Main difference for 3, 2 and 1 PORVs open
- Below cases with central UPs
- HAs are injecting ( $P < 60 \text{kgf/cm}^2$ )

## RCS pressure

- 3 PORVS – faster decrease
- 2 PORVS – smooth decrease
- 1 PORV – periodical decrease-increase (long periods)



## Core level

- 3 PORVS – low
- 2 PORVS – long half-core
- 1 PORV – periodic full and dry core


# Uncertainty Analysis Results Example

## Uncertainty analysis results example (H2 generation in reactor)


- Can be given as mean with tolerance limits (0.95, 0.95)

### “Mixed” PORVs set

- Mean 529kg
- Median 503kg
- TL 369kg, 812kg
- Std. dev. 106kg



Hydrogen generated in the core, kg (runs)



Hydrogen generated in the core




# Sensitivity Analysis Results Example

## Sensitivity analysis results (Pearsons, H2 generated in reactor)


Scalar sensitivity analysis

Consequence 2 (no Transf.); 43 parameters considered; n =100; R\*\*2=0.6466




Scalar sensitivity analysis

Consequence 2 (no Transf.); 43 parameters considered; n =100; R\*\*2=0.6517



Scalar sensitivity analysis

Consequence 2 (no Transf.); 43 parameters considered; n =100; R\*\*2=0.7629




### Outcomes:

- Each equipment configuration has its own **main** sensitivities
- Mixed analysis sensitivities are VERY different


Scalar sensitivity analysis

Consequence 2 (no Transf.); 43 parameters considered; n =100; R\*\*2=0.8586




# Sensitivity Analysis Results Example


## H<sub>2</sub> generated in reactor, scatter plots



**3 PORVs open (100runs)  
DTMAX**



**2 PORVs open (100runs)  
Decay heat**



**1 PORV open (100runs)  
Actions delay**


### Outcomes:

- MELCOR results scatter
- H<sub>2</sub> depends on DTmax for 3 PORVs
- Scatter plots are useful

# Sensitivity Analysis Results Example


## Example scatter plots (high VS low scatter results)

### moderate scatter




2 PORVs open (100runs)  
H<sub>2</sub> in cavities from  
Decay heat

### high scatter



1 PORV open (100runs)  
H<sub>2</sub> in cavities from  
Decay heat

### low scatter



1 PORV open (100runs)  
Gap release time from  
Decay heat

## Outcomes:





- MELCOR results scatter depends on parameters and time
- Sequence-dependent sensitivities

# Sensitivity Analysis Results Example

**CFVS open time, scatter plots (dep. on Open setpoint and Decay heat)**

**Outcomes:**


- CFVS can open early and later
- With increase of decay heat open time decreases




**CFVS open time**

# Sensitivity Analysis Results Example


## RV failure time, scatter plots (from Decay heat)



3 PORVs open (100runs)




2 PORVs open (100runs)



1 PORV open (100runs)

### Outcomes:


- RV vessel failure time is very scattered for 1 PORV
- RV vessel failure time is low dependent on decay heat for 2 PORVs




Mixed PORVs open

# Sensitivity Analysis Results Example


## RV failure time, scatter plots (from DTMAX - timestep)



3 PORVs open (100runs)




2 PORVs open (100runs)



1 PORV open (100runs)

### Outcomes:

- No DTmax dependence
- Large scatter for 1 PORV



Mixed PORVs open

DTMAX, s #37



# Sensitivity Analysis Results Example

## CAV1 ablation depth, scatter plots (from Overflow height)



### Outcomes:

- For 3 PORVs statistically ablation in CAV1 is stopped for overflow height less than 0.25m with maximal ablation depth 0.46m
- For 2 PORVs cases statistically ablation in CAV1 is stopped for overflow height less than 0.29m with max ablation depth 0.48m

3 PORVs open (100runs)






2 PORVs open (100runs)



# Code-model numerical noise/scatter

## Code/model numerical noise/scatter estimation

- Performed for 3 PORVs with 0.1s base DTmax
- DTmax is changed by 1e-8s ... 0.02s both ways
- Analyzed only calcs without code stop (one-through)











H2 generated in reactor



# Code-model numerical noise/scatter

## Code/model numerical noise/scatter estimation



H2 generated in cavities

CFVS open time

RV failure time


CFVS filter load

# Code-model numerical noise/scatter

## Code/model numerical noise/scatter estimation

### Outcomes:

- The code result does NOT converge to base value (always scattered, tends to decrease)
- This scatter is anavoidable
- Scatter of MELCOR results CAN NOT be LESS than code/model noise
- Scatter can mask the correlation




H2 generated in reactor


# Code-model failure rate

## Code/model success statistics

- Performed for 3 PORVs noise
- Successful and failed cases statistics



Code stop time EDF



## Outcomes:

- Total 221 cases run, 77 success (**35%**), 144 failed (**65%**)
- Code fails in decreasing order of priority at
  - Core degradation phase
  - Early ex-vessel phase
  - Early TH phase
  - Late ex-vessel phase

# MELCOR Uncertainty/Sensitivity Analysis Applications



## Importance parameters ranking for FOMs

Can be used to estimate:

- Parameter important or not
- Areas of deeper modeling needed
- Areas of simpler modeling

## Examples of LOW sensitivity

- Time of gap release from actions delay (1 PORV)
- LH failure time from decay heat (2 PORVs)





# MELCOR Uncertainty/Sensitivity Analysis Applications

## Importance parameters ranking for FOMs

### Examples of HIGH sensitivity

- Ablation depth in cavity from melt overflow height (3 PORVs)
- H<sub>2</sub> generated in cavity from melt overflow height (3 PORVs)



# MELCOR Uncertainty/Sensitivity Analysis Applications

## Important parameters for FOMs (table below)


- Detectable high sensitivity in MELCOR calculations
- In table N PORVs for sensitive cases
- Other sensitivities are not detected (<0.2)
- Reasons not detecting – No any OR code-model scatter

Param.	Xe release	Cs release	Gap time	H2 reactor	H2 cavities	CFVS time	LH time	CAV abl.	CFVS load
#13, Decay heat	3,2,1	2,1	3,2,1	2	3,2,1	3,2,1	3,1		2,1
#20, Zr upper Temperature				3					
#28, COR porosity				2					
#33, CAV overflow height	2				3,2,1			3,2,1	
#36, CFVS open P						3,2,1			
#37, DTMAX				3					
#39, PORV open delay		1	3	1					1


# MELCOR Uncertainty/Sensitivity Analysis Applications

## SAMGs optimization


- Use of population MEAN values
- Lowest Cs release to ENV for 3 PORVs (optimal)
- Lowest H<sub>2</sub> generation for 3 PORVs (optimal)
- Lowest CFVS filter load for 3 PORVs (optimal)
- But for 3 PORVs the earliest RV failure ! (optimal?)



Cs release to environment, %



CFVS filter thermal load




H<sub>2</sub> generated in core

# MELCOR Uncertainty/Sensitivity Analysis Applications

## SAMGs optimization

- Scatter plot of analysis can show **optimal** areas of actions
- Example for gap release time
- For operator delay 0...600s the gap release is always later (**optimal**)
- Strategy choice justification




Gap release time depending on PORV operator actions delay



# MELCOR Uncertainty/Sensitivity Analysis Applications

## Setpoints optimization

- Scatter plot of analysis can show **optimal** setpoints
- Example for CFVS open time
- Setpoint  $>5.3\text{kgf/cm}^2$  would statistically exclude early CFVS opening for 3 PORVs




CFVS open time (FOM7) depending on parameter #36  
(CFVS\_Open\_P - CFVS opening pressure setpoint)


# MELCOR Uncertainty/Sensitivity Analysis Applications

## Sensitivity analysis for code improvement

- Performed for 3 PORVs
- See the time-dependent correlation analysis for H<sub>2</sub> generated in core



PCC for hydrogen generated in the core



## Outcomes:

- Correlation to DTmax starts to grow at early ex-vessel phase
- MELCOR code H<sub>2</sub> in core generation algorithm should be **checked** at this phase

# Conclusions

## MELCOR concerned conclusions

- MELCOR code is a **powerful** integral tool for uncertainty/sensitivity analysis
- MELCOR results have **anavoidable** scatter (verified)
- MELCOR scatter is **different** for different parameters and can mask the correlations
- MELCOR scatter range **increases** with transient progression (high after core damage)
- MELCOR UA results are powerful for SAMG **optimization** in statistical manner
- MELCOR run failures rate depends on the modeling but still significant
- MELCOR sensitivity analysis can be used for code **improvement**
- MELCOR application results are presented in CSARP in-kind report “Uncertainty and Sensitivity Analysis for VVER-1000 SBO Accident with Personnel Actions by MELCOR code. Methods, Insights and Conclusions”

# Thank you for your time!

Please subscribe:

 [sstc.ua](http://sstc.ua)

 [sstc.com.ua](http://sstc.com.ua)

 [SSTC\\_NRS](https://twitter.com/SSTC_NRS)

 [SSTC NRS](https://www.youtube.com/SSTC_NRS)

 [nrs@sstc.ua](mailto:nrs@sstc.ua)